
Module Front



LED Indicators


LED no	Indication	Meaning
1 (Network Status)	Off Green Flashing green Red Flashing red	Not online Link ok, online, connected Online, not connected Critical link failure Connection timeout
2 (Module Status)	Off Green Flashing green Red Flashing red	No power Device operational Data size bigger than configured Unrecoverable fault Minor fault
3, 4 (Not used)	-	-
5 (Subnet Status)	Flashing green Green Red	Running, but one or more transaction errors Running Transaction error/timeout or subnet stopped
6 (Device Status)	Off Alternating red/green Green Flashing green Red Flashing red	Power off Invalid or missing configuration Initializing Running Bootloader mode Note the flash sequence pattern and contact the HMS support department

Configuration Switches

Sw. 1	Sw. 2
OFF	OFF
OFF	ON
ON	OFF
ON	ON
	OFF OFF ON

Mac ID	Sw. 3	Sw. 4	Sw. 5	Sw. 6	Sw. 7	Sw. 8
0	OFF	OFF	OFF	OFF	OFF	OFF
1	OFF	OFF	OFF	OFF	OFF	ON
2	OFF	OFF	OFF	OFF	ON	OFF
3 - 62						
63	ON	ON	ON	ON	ON	ON

DeviceNet Connector



Pin no	Description
1	V-
2	CAN L
3	Shield
4	CAN H
5	V+

Accessories Checklist

The following items are required for installation:


- Anybus Communicator Resource CD (Includes configuration software, manuals, EDS file and application notes)
- RS232 configuration cable
- Subnetwork connector
- DeviceNet network cable and connector (not included)

Installation and Startup Summary

- Mount the Communicator on the DIN-rail.
- Connect the Communicator to the DeviceNet network.
- Connect the Communicator to the subnetwork.
- Power on the Communicator (+24 V DC).
- Connect the configuration cable between the Communicator and the PC containing the Anybus Configuration Manager software (ACM).
- Configure the Communicator using ACM.
- Include the Anybus Communicator EDS file in the DeviceNet configuration tool.
- Configure and start the DeviceNet network.

Further information and documents about this product can be found at the product pages on www.anybus.com.

Bottom View



Subnetwork Connector

Subnet	letwork Connector	
Pin no.	Description	
1	+5V OUT	
2	RS232 Rx	
3	RS232 Tx	
 4	NC	
5	Signal GND	
6	RS422 Rx+	
7	RS422 Rx-	
8	RS485+ / RS422 Tx+	
9	RS485- / RS422 Tx-	

SP0638, Rev. 1.20, Mar 2015 www.anybus.com

Anybus Communicator Installation Sheet

UL Certification



IND: CONT. EQ. FOR HAZ LOC. CL I, DIV 2 GP A,B,C,D TEMP CODE E203225

Warnings

- WARNING EXPLOSION HAZARD SUBSTITUTION OF ANY COMPONENTS MAY IMPAIR SUITABILITY FOR CLASS I, DIVISION 2.
- WARNING EXPLOSION HAZARD WHEN IN HAZARDOUS LOCATIONS, TURN OFF POWER BEFORE REPLACING OR WIRING MODULES.
- WARNING EXPLOSION HAZARD DO NOT DISCONNECT EQUIPMENT UNLESS POWER HAS BEEN SWITCHED OFF OR THE AREA IS KNOWN TO BE NONHAZARDOUS.

Attention!

- ATTENTION RISQUE D'EXPLOSION LE REM-PLACEMENT DE TOUT COMPOSANTS INVALIDE LA CERTIFICATION CLASS I, DIVISION 2.
- ATTENTION RISQUE D'EXPLOSION EN ZONE EXPLOSIVE, VEUILLEZ COUPER L'ALIMENTATION ÉLECTRIQUE AVANT LE REMPLACEMENT OU LE RACCORDEMENT DES MODULES.
- ATTENTION RISQUE D'EXPLOSION NE PAS DÉCONNECTER L'ÉQUIPEMENT TANT QUE L'ALIMENTATION EST TOUJOURS PRÉSENTE OU QUE LE PRODUIT EST TOUJOURS EN ZONE EXPLO-SIVE ACTIVE.

Additional installation and operating instructions

Max Ambient Temperature: 55°C (for Hazloc environments)

Field wiring terminal markings (wire type (Cu only, 14-30 AWG)).

Use 60/75 or 75°C copper (Cu) wire only.

Terminal tightening torque must be between 5-7 lb-in (0.5 - 0.8 Nm).

Use in overvoltage category 1 pollution degree 2 environment.

Installed in an enclosure considered representative of the intended use.

Secondary circuit intended to be supplied from an isolating source and protected by overcurrent protective devices installed in the field sized per the following:

Control-circuit Wire Size		Maximum Protective Device Rating
AWG	(mm²)	Amperes
22	(0.32)	3
20	(0.52)	5
18	(0.82)	7
16	(1.3)	10
14	(2.1)	20
12	(3.3)	25

EMC Compliance (CE)



This product is in accordance with the EMC directive 89/336/EEC, with amendments 92/31/EEC and 93/68/EEC through conformance with the following standards:

- EN 50082-2 (1993) EN 55011 (1990) Class A
- EN 61000-6-2 (1999)
 EN 61000-4-3 (1996) 10 V/m
 EN 61000-4-6 (1996) 10 V/m (all ports)
 EN 61000-4-2 (1995) ±8 kV Air Discharge
 ±4 kV Contact discharge
 EN 61000-4-4 (1995) ±2 kV Power port
 ±1 kV Other ports
 - EN 61000-4-5 (1995) ±0.5 kV Power ports (DM/CM) ±1 kV Signal ports

ODVA Compliance



DeviceNet CONFORMANCE TESTED $^{\mathrm{TM}}$ is a certification mark of ODVA.

Further information and documents about this product can be found at the product pages on www.anybus.com.