

Modbus Plus Slave - LonWorks



The Anybus X-gateway copies I/O-data in both directions thus enabling data exchange between the two networks. Default I/O configuration is 20 bytes Input and 20 bytes Output. Changing default settings is very simple and is carried out using the RS232 configuration port and a standard terminal interface on a PC, such as Hyper Terminal for Windows.

The Modbus Plus interface is based on licensed chip-set and software from Modicon Inc. Supporting both the Global Database and Register mapping to 3x and 4x registers this module implements a versatile Modbus Plus interface. The Modbus Plus interface module is certified by the Modconnect and has proven conformance and interoperability with leading PLC's, HMI's etc

The LonWorks interface is a high performance interface to LonWorks networks. The interface supports LonMark objects handling. The required network variables on the LonWorks side can be configured and stored in FLASH. It is based on MIP that allows high throughput and a configurable set of up to 256 input and 256 output network variables. The interface can, via the "LWtool" PC-based configuration utility program, link, and convert data between the other network side and devices located on a LonWorks Network. The LonWorks side of the product can be configured for any type of network variable e.g. SNVT's or UNVT's.

KEY FEATURES

- Modbus Plus Global Data Base Transaction, Point-to-Point commands, Read holding registers, Preset single register
- Modbus Plus Host Firmware Rev. 77
- Special LW Config Software Tool for Network variable Setup
- Certification prepared for Lonmark application layer interoperability guidelines V3.2
- LonWorks FT-X1 Transceiver

TECHNICAL SPECIFICATIONS

Size:	126 mm x 110 mm x 42 mm
Power Supply:	24 VDC (±10%)
Temperature:	0-65°C
Current Consump:	max 300 mA
I/O Input:	Default 20 bytes, max 512 bytes (max 64 bytes as Modbus Plus Global Data, max 256 network variables on LonWorks)
I/O Output:	Default 20 bytes, max 512 bytes (max 64 bytes as Modbus Plus Global Data, max 256 network variables on LonWorks)
Mech Rating:	IP20/Nema1
Config Method:	Windows Hyper Terminal
UL certification:	E203225, Listed 67AM, UL-1604 Class 1, Div 2, GP A, B, C, D, Temp Code T4
ATEX certification:	ATEX 135419, II 3 G, EEx nL IIC T4, DEMKO 03
Power supply connector:	2-pole 5.08 mm Phoenix pluggable screw connector
Modbus Plus baudrate:	1 Mbit/s
Modbus Plus address:	Node-ID and Source-ID 1-64
ModbusPlus connector:	D-sub 9-pin female
LonWorks baudrate:	78 kbit/s
LonWorks Connector:	5-pole 5.08 mm Phoenix pluggable screw connector
LonWorks config.:	Contact HMS (LW Tool for LonWorks interface variable configuration)
Price Group:	C
Order Code:	AB7625